



## Assessment Table

**Table 1: Low Risk Test**

		Yes	No
1.1	is the area of land disturbance > 1000 m <sup>2</sup> ?		
1.2	does any land disturbance occur in a BCC mapped waterway corridor?		
1.3	is there any slope on site (longer than three metres in length) before, during or after construction that is steeper than 5%?		
1.4	does any land disturbance occur below 5 m AHD?		
1.5	does development involve endorsement of a staging plan?		
1.6	is there an upstream catchment passing through the site > 1 hectare?		

If you answered '**No**' to **ALL** of these questions, then the site is **low risk** with respect to erosion and sediment control.  
(Do not continue to Table 2)

If you answered '**Yes**' to **ANY** of these questions, then proceed to **Table 2**

**Table 2: Medium Risk Test**

		Yes	No
2.1	is the area of land disturbance > 1 hectare?		

If '**No**' then the site is **medium risk** with respect to erosion and sediment control.  
(Do not continue to Table 3)

If '**Yes**' then proceed to **Table 3**

**Table 3: High Risk Test**

		Yes	No
3.1	is there an upstream catchment passing through the site > 1 hectare?		
3.2	does any land disturbance occurs in a BCC mapped waterway corridor?		
3.3	is there any slope on site (longer than three metres in length) before, during or after construction that is steeper than 15%?		

If you answered '**No**' to **ALL** of these questions, then the site is also **medium risk** with respect to erosion and sediment control.

If you answered '**Yes**' to **ANY** of these questions, then the site is **high risk** with respect to erosion and sediment control.